




DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54



TEST REPORT			
Sample ID	Ref. No. D.J.B/DTQC/Wzd./2024-25/Paid-261-62		
Location /Address of Sample	Prudence School, PS-2, C-3, Block, Ashok Vihar, Phase-II, Delhi-110052		
Letter Reference No.	--	Ref. Letter Date	13.03.2025
Challan No.	284	Challan Date	18.03.2025
Sample Collection date	19.03.2025	Analysis start date	19.03.2025
Any other Information	--	Analysis end date	21.03.2025
		Reporting date	22.03.2025

TEST RESULTS						
S.No	Parameters	Unit	As per the IS 10500		Inlet (Storage tank)	Outlet (RO) (Drinking water tap)
			Acceptable limit	Permissible limit		
1	Colour	CU	5(Max)	15(Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	4.0	1.5
4	pH at 25 °C	--	6.5-8.5	No relaxation	7.46	7.12
5	Electrical Conductivity	µS/cm	-	-	297	85
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	193	55
7	Total Alkalinity	mg/L	200(Max)	600(Max)	94	16
8	Total Hardness	mg/L	200(Max)	600(Max)	124	4
9	Calcium as Ca	mg/L	75(Max)	200(Max)	27.2	0.8
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	13.4	0.5
11	Iron	mg/L	1.0(Max)	No relaxation	0.08	0.04
12	Chloride	mg/L	250(Max)	1000(Max)	22	27
13	Fluoride	mg/L	1.0(Max)	1.5(Max)	0.36	0.02
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate	mg/L	45(Max)	No relaxation	6.9	1.2
16	Sulphate	mg/L	200(Max)	400(Max)	46.6	1.0
17	Residual Chlorine	mg/L	0.2(Min.)	1.0(Max)	BDL	BDL
18	Coliform Count at 37°(MPN)	/100 mL	Absent	No relaxation	0	0

*BDL=Below Detection Limit

End of Report

Remarks: Samples collected confirms specification for tested parameters and can be considered for the drinking purpose.

Tested by
Lab.Tech.

Verified for Chemical parameters
Asstt.Chemist

Verified for MPN
Asstt.Bact.Chemist

Authorized by

Asstt. Chief Water Analyst
D.J.B. (Govt. of N.C.T. of Delhi)
Water Works, Wazirabad

Dr. C.B. MISHRA
PRINCIPAL
PRUDENCE SCHOOL
PS-2, C-3, ASHOK VIHAR,
PH-2, DELHI-110052

Scanned with CamScanner

19/03/2025

DELHI JAL BOARD 9^{Am}
WATER WORKS WAZIRABAD
DELHI - 110054
Cash/raft/C.D.R.

Challan No.284 Dated:18.03.2025

Name of Depositor	Description	Amount
CBF No. 157 for Received Rs. 1640 Challan No. 284 Date 18/2/2025 Prudence School, P.S- 2, C-3, Ashok Vihar-II, Delhi, 110052	Testing fee for 02 Nos. of water sample Chemical & Bacteriological for drinking purpose (Sample collection and transportation will be facilitated by School)	1640/= (One Thousand Six Hundred Forty Rupees only)


[Signature] 18/3/25
Chemist/Bacteriologist

[Signature]
01.05.2025
Dr. C.B. MISHRA
PRINCIPAL
PRUDENCE SCHOOL
ASHOK VIHAR,
DELHI

Scanned with CamScanner



MUNICIPAL CORPORATION OF DELHI
Public Health Department, Keshav Puram Zone
Office of the Deputy Health Officer
A-1 Block, Keshavpuram, Delhi-110035
E-mail : dhokpz@gmail.com




No. DHO/KPZ/2025/1337

Dated: 28/3/25

SCHOOL HEALTH CERTIFICATE

1. Name of the School: PRUDENCE SCHOOL
2. Address of School: PS-2, C3 BLOCK, ASHOK VIHAR PH-II, DELHI-110052
3. No of Shifts: ONE Timing: 08:00 AM TO 02:00 PM
4. No. of Students: Boys: 1887 Girls: 1410 Total: 3297
5. No. of Staff: Male: 21 Female: 116 Total: 137
6. Accommodation provided are as under:-

- ❖ Classrooms are well ventilated and well lighted.
- ❖ Floor areas in the classrooms are sufficient
- ❖ Classrooms are kept neat and clean.
- ❖ Building /Classrooms do not require white wash.
- ❖ Drinking water is wholesome.
- ❖ Latrine arrangement is sanitary.
- ❖ Number of Latrines and Urinals are sufficient.
- ❖ Separate toilet arrangements for Boys & Girls are available.
- ❖ Separate toilet arrangement for staff is available.
- ❖ The overall facilities are adequate.


Deputy Health Officer
Keshav Puram Zone
 Deputy Health Officer
Keshav Puram Zone
Municipal Corporation of Delhi

REMARKS: THIS CERTIFICATE IS VALID FOR ONE YEAR FROM THE DATE OF ISSUANCE.


01.05.2025
Dr. C.B. MISHRA
PRINCIPAL
PRUDENCE SCHOOL
PS-2, C3, ASHOK VIHAR,
PH-II, DELHI-110052